



133/ts/jasenica\_lucky  
 exist. - kioska TS MKP800  
 dem. TR 160 kVA  
 mont. TR 250 kVA, 22/0,40kV  
 dem. poistky VN  
 mont. poistky VN 16A  
 exist. Rozv. NN - In=630A  
 Hl. deon nastavit na Ir=361A

### LEGENDA:

- EXIST. PODZEMNE VN VEDENIE
- EXIST. PODZEMNE NN VEDENIE
- EXIST. KIOSKOVA TS



HLAVNY INZINIER PROJEKTU	ZODP.PROJ.	Ing. Michal Borsik	PETROSTAV SK, s.r.o.	
	KRESLIL	Ing. Michal Borsik		
STAVITEL SSD, o.s.				
STAVBA  <b>15606 - Jasenica - Lucky - Rozsirenie NNK</b>			DÁTUM	03 / 2023
			FORMÁTY	A4
			PROFESIA	EL
			STUPEŇ	PD pre realizáciu
			MIERKA	1 : 500
OBSAH VYKRESU			CISLO VYKRESU	
Situacia - montaz c.1				2